

WINNEMUCCA CITY OF

Consumer Confidence Report – 2018

Covering Calendar Year – 2017

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. It is important that customers be aware of the efforts that are continually being made to improve their water systems. To learn more, please attend any of the regularly scheduled City Council meetings held on the first and third Tuesday of the month at 2:00 p.m. **For more information please contact the City of Winnemucca City Manager/Engineer Alicia Heiser at (775) 623-6333.**

Your water comes from:

Source Name	Source Water Type
WELL 5	Ground Water
RAILROAD SPRING	Ground Water
WELL 6	Ground Water
WELL 2A	Ground Water
WELL 7	Ground Water
WELL 4	Ground Water

We add disinfectant to your water to protect you against microbial contaminants. The Safe Drinking Water Act (SDWA) requires states to develop a Source Water Assessment (SWA) for each public water supply that treats and distributes raw source water in order to identify potential contamination sources. The state has completed an assessment of our source water. For results of the source water assessment, please contact us.

Message from EPA

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and

wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides may come from a variety of sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, can be naturally occurring or the result of mining activity

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, may also come from gas stations, urban storm water run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation which limits the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system tested a minimum of 10 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presences in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public by newspaper, television or radio.

Water Quality Data

The tables following below list all of the drinking water contaminants that were detected during the 2017 calendar year. The presence of these contaminants does not necessarily indicate that the water poses a health risk. Unless noted, the data presented in this table is from testing done January 1- December 31, 2017. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**

Terms & Abbreviations

Maximum Contaminant Level Goal (MCLG): the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.

Maximum Contaminant Level (MCL): the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.

Action Level (AL): the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT): a treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG’s do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Non-Detects (ND): laboratory analysis indicates that the constituent is not present.

Parts per Million (ppm) or milligrams per liter (mg/l)

Parts per Billion (ppb) or micrograms per liter (µg/l)

Picocuries per Liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

Millirems per Year (mrem/yr): measure of radiation absorbed by the body.

Million Fibers per Liter (MFL): million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU): nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.



Testing Results for WINNEMUCCA CITY OF

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in the Calendar Year of 2017				

Disinfection By-Products	Monitoring Period	Range	Unit	MCL	MCLG	Typical Source
TTHM	2017	2.5	ppb	80	0	By-product of drinking water chlorination
HAA5	2017	6	ppb	60	0	By-product of drinking water chlorination

Lead and Copper	Date	90 TH Percentile	Unit	AL	Sites Over AL	Typical Source
COPPER	06/13/2016	0.100	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
LEAD	06/13/2016	0.002	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
------------------------	-----------------	---------------	-------	------	-----	------	----------------

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
ARSENIC	02/02/2016	8	0-8	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
BARIUM	04/04/2017	0.06	0.06	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
CHROMIUM	04/04/2017	2	2	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.
FLUORIDE	04/04/2017	0.3	0.1-0.3	ppm	2	4	Natural deposits; Water additive which promotes strong teeth.
NICKEL	07/18/2017	8	1-8	ug/L	N/A	N/A	
NITRATE	03/08/2017	6.5	0-340	Ppb	10000	10000	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED URANIUM	02/02/2016	7	7	µg/L	30	0	Erosion of natural deposits
GROSS ALPHA, INCL. RADON & URANIUM	04/19/2016	8.1	1.1-8.1	pCi/L	15	0	Decay of natural and man-made deposits
GROSS BETA PARTICLE ACTIVITY	05/11/2015	2.3	2.3	pCi/L	50	0	Decay of natural and man-made deposits

Secondary Contaminants	Collection Date	Highest Value	Range	Unit	SMCL	MCLG
CHLORIDE	07/18/2017	220	13-220	mg/L	400	
MAGNESIUM	07/18/2017	32	16-32	mg/L	150	
pH	06/06/2017	8.11	8.03-8.11	pH	6.5-8.5	
SODIUM	07/18/2017	64	15-81	mg/L		
SULFATE	07/18/2017	95	45-95	mg/L	500	20
TDS	07/18/2017	700	300-700	mg/L	1000	

Health Information About Water Quality

Additional Required Health Effects Language:

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Violations

During the 2017 calendar year, WINNEMUCCA CITY OF is required to include an explanation of the violation(s) in the table below and the steps taken to resolve the violation(s) with this report.

Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2017			

Health Information About the Above Violation(s)

There are no additional required health effects violation notices.

Water System Contact Information

Water System Name: City of Winnemucca

BSDW System ID Number: NV0000248

Number of Connections: 3300

Owner's Rep: Alicia Heiser

E-mail: wmcaah@winnemuccacity.org

Operator: Roger Sutton

Address: 90 W. 4th street, Winnemucca, NV 89445

County: Humboldt

Population Served: 9900

Fax: 775-623-6321

Telephone: 775-623-6333

Telephone: 775-623-6381

Fax: 775-623-6321