



**STATE OF NEVADA**  
Department of Conservation & Natural Resources  
**DIVISION OF ENVIRONMENTAL PROTECTION**

Brian Sandoval, Governor  
Leo M. Drisdoff P.E., Director  
Colleen Cripps, Ph.D., Administrator

June 17, 2013

City of Winnemucca  
Steve West  
90 W 4<sup>th</sup> Street  
Winnemucca, NV 89445

**RE: BOIL WATER ORDER RESCINDED**  
**CITY OF WINNEMUCCA- PWS I.D. # NV0000248 - C - HUMBOLDT COUNTY**

Dear Mr. Steve West,

The precautionary "Boil Water Order" issued to the CITY OF WINNEMUCCA water system on June 14, 2013 is **hereby rescinded**. Bacteriological test results indicate that E. coli and other coliform bacteria are not present in the system. The test results are as follows:

Date	Number of Samples	Results
6/15/2013	5	Absent
6/16/2013	5	Absent

Thank you for your cooperation in notifying your customers.

Sincerely,

Latricia Lord, Environmental Scientist III, Bureau of Safe Drinking Water  
[llord@ndep.nv.gov](mailto:llord@ndep.nv.gov)

cc: Bert Bellows, Facility Manager, Bureau of Safe Drinking Water  
Jennifer Carr, Chief, Bureau of Safe Drinking Water  
Andrea Seifert, Supervisor, Bureau of Safe Drinking Water  
Dave Emme, Deputy Administrator, NDEP  
JoAnn Kittrell, PIO, NDEP  
Colleen Cripps, Administrator, NDEP  
Joe Pollock, Cindy Ulich, Nevada State Health Division  
Rick Sowadsky, Nevada State Health Division

FAX (775) 687-5699